

TEST PROCEDURES FOR **PATTERN APPROVAL** AND THE VERIFICATION OF WATER METER

Presented by

MOHD NOOR GHAFAR
WATER FLOWMETER LABORATORY, FLOW GROUP
NATIONAL METROLOGY INSTITUTE OF MALAYSIA
16th OCTOBER 2019

MEDEA Training on Pattern Approval and
Verification of Water Meters – OIML R49



All rights reserved. © 2019 SIRIM Berhad.

Overview



```
graph TD; A[Overview] --> B[Standards]; B --> C[Procedure];
```

Standards

Procedure

OVERVIEW: TYPE EVALUATION TESTS FOR WATER METERS

WATER METER CALIBRATION FACILITY



Enabling Businesses. Enhancing Lives

PERFORMANCE TESTS FOR ALL TYPE WATER METER

No.	Test	Sub-clause	No. of Meters
1	Static pressure	7.3	All
2	Error (of indication)	7.4	All
3	Absence of flow	8.17	≥ 1
4	Water temperature	7.5	≥ 1
5	Overload water temperature	7.6	≥ 1
6	Water pressure	7.7	≥ 1
7	Reverse flow	7.8	≥ 1
8	Pressure loss	7.9	≥ 1
9	Flow disturbance	7.10	≥ 1
10	Discontinuous flow durability test at $Q_3 (\leq 16 \text{ m}^3/\text{h}) / Q \geq 2 Q_{x2}$	7.11.2	≥ 1 ieao
11	Continuous flow durability test at $Q_3 (Q_3 > 16 \text{ m}^3/\text{h})$	7.11.3	≥ 1 ieao
12	Continuous flow durability test at Q_4	7.11.3	≥ 1 ieao
13	Continuous flow durability test at $0.9 Q_{x1}$	7.11.3	≥ 1 ieao
14	Magnetic field testing	8.16	≥ 1

ieao: in each applicable orientation

LAB BASIC SAFETY GUIDELINES

- ✓ Perform only those testing authorized by the instructor. Never do anything in the testing laboratory. Carefully follow ALL instructions, written and oral. Unauthorized testing are prohibited.
- ✓ Shoes must completely cover the foot. Sandals are NOT allowed.
- ✓ If any Test Bench equipment is malfunctioning, making strange noises from the pumps, sparking, smoking, smells "funny," from the control panel, get an instructor or staff immediately. It is imperative that the instructor or staff knows of any equipment problems.
- ✓ All accidents, no matter how minor, should be reported to the staff member supervising the laboratory immediately.
- × Please don't yell, scream, or make any sudden loud noises that could startle others who are concentrating on their work.
- × Do not use any equipment unless you are trained and approved as a user by your instructor or staff. Ask questions if you are unsure of how to operate something.
- × Don't eat, drink, or smoke.

- ✓ Minimum number of meters to be tested for all meter types:

Meter Designation, Q_3 [m ³ /h]	Minimum Number of Meters
$Q_3 \leq 160$	3
$160 < Q_3 \leq 1\,600$	2
$1\,600 < Q_3$	1

- ✓ excluding the tests required for meters with electronic devices (**5** samples)

Table 6 OIML R49-1:2013 7.2.2

CALIBRATION STANDARDS & INSTRUMENTS

- ✓ test rig
- ✓ water supply (tank, pump)
- ✓ pipework
- ✓ calibrated reference (tank, balance, meter)
- ✓ pressure sensor
- ✓ temperature sensor
- ✓ stopwatch

INSTRUMENTS – Platform Balance



INSTRUMENTS – Pump



INSTRUMENTS – Temperature Sensor



INSTRUMENTS –Pressure Sensor



TRACEABILITY CHART

SI Units

kg

K

s

Pa

National
Standard of
Mass
Heavy Mass
Laboratory,
NMIM

National
Standard of
Temperature
Radiation
Thermometry
Laboratory,
NMIM

National
Standard of
Time
Time &
Frequency
Laboratory,
NMIM

National
Standard of
Pressure
Low
Pressure
Laboratory,
NMIM

PLATFORM
BALANCE

TEMPERATURE SENSOR

STOPWATCH

PRESSURE SENSOR

WATER FLOW CALIBRATION SYSTEM

CALIBRATION **PROCEDURES**

DETERMINATION OF INTRINSIC ERRORS TEST

OBJECTIVE

- ✓ To determine the intrinsic errors (of indication) of a water meter and the effects of the meter orientation on the error (of indication).

- ✓ The method specified here for determining the meter errors (of indication) is the so – called “**COLLECTION**” method, in which the quantity of water passed through a water meter is collected in one or more collecting vessels and the quantity determined volumetrically or by weighing.

OIML49-2:2013 7.4.1

OIML R49-2:2013 7.4.2.1

Standing-Start-and-Finish

- ✓ Tests with readings taken with the meter at rest
- ✓ Flow is established by opening a valve, situated downstream of the meter, and it is stopped by closure of this valve. The meter is read when the registration is stationary

Flying-Start-and-Finish

- ✓ Tests with readings taken under stable flow conditions and diversion of flow
- ✓ The measurement is carried out when flow conditions have stabilized.
- ✓ The meter is read while in motion.

OIML R49-2:2013 7.4.2.2.5

- ✓ Check that the operation of the test rig is such that, during a test, the actual volume of water that flows through the meter(s) is equal to that measured by the reference device.
- ✓ Check that the pipe (e.g. the swan-neck in the outlet pipe) is filled to the same datum level at the beginning and at the end of the test.
- ✓ Bleed all air from the interconnecting pipework and the meter(s).
- ✓ Take all precautions necessary to avoid the effects of vibration and shock.

OIML R49-2:2013 7.4.2.2.3

RATED OPERATING CONDITIONS

Flow Rate Range	Q_1 to Q_3 inclusive
Ambient Temperature Range	+ 5 °C to + 55 °C
Water Temperature Range	Table 1
Ambient Relative Humidity	0 % to 100 % 0 % to 93 % (remote)
Pressure Range (DN < 500 mm)	0.03 MPa to at least 1 MPa
Pressure Range (DN ≥ 500 mm)	0.03 MPa to at least 0.6 MPa

OIML R49-1:2013 6.4

MAJOR FACTORS AFFECTING THE MEASUREMENT OF ERRORS

- ✓ Supply pressure
- ✓ Flow rate
- ✓ Temperature
- ✓ Orientation of water meter(s)
 - ✓ H: Horizontal
 - ✓ V: Vertical
 - ✓ Unmarked:
V / H / 45°



- a) Determine the intrinsic errors (of indication) of a water meter (in the measurement of the actual volume), for at least the following flow rates, the error at each flow rate being measured 3 times for 1), 2) and 5) and twice for other ranges:

- 1) Q_1 to $1.1 Q_1$;
- 2) Q_2 to $1.1 Q_2$;
- 3) $0.33 \times (Q_2 + Q_3)$ to $0.37 \times (Q_2 + Q_3)$;
- 4) $0.67 \times (Q_2 + Q_3)$ to $0.74 \times (Q_2 + Q_3)$;
- 5) $0.9 Q_3$ to Q_3 ;
- 6) $0.95 Q_4$ to Q_4 ;

and for combination meters:

- 7) $0.85 Q_{x1}$ to $0.95 Q_{x1}$;
- 8) $1.05 Q_{x2}$ to $1.15 Q_{x2}$

OIML R49-2:2013 7.4.4

- b) Test the water meter without its supplementary devices attached (if any).
- c) During a test, hold all other influence factors at reference conditions.
- d) Measure the errors (of indication) at other flow rates if the shape of the error curve indicates that the MPE may be exceeded.
- e) Calculate the relative error (of indication) for each flow rate in accordance with Annex B.
- f) Complete the test report

MARKS AND INSCRIPTIONS FOR A METER WITHOUT ELECTRONIC DEVICE



BRAND : Delta MTR
 $Q_3 = 4 \text{ m}^3/\text{hr}$
Ratio = R160
DN20



BRAND : DP MTR
 $Q_3 = 2.5 \text{ m}^3/\text{hr}$
Ratio = R400
DN15

MARKS AND INSCRIPTIONS FOR A METER WITHOUT ELECTRONIC DEVICE




BRAND : GLMJ2
 $Q_3 = 2.5 \text{ m}^3/\text{hr}$
Ratio = R80
DN15



BRAND : DP MTR
 $Q_3 = 4 \text{ m}^3/\text{hr}$
Ratio = R200
DN20

MARKS AND INSCRIPTIONS FOR A METER WITHOUT ELECTRONIC DEVICE



BRAND : DIEHL Metering
 $Q_3 = 4 \text{ m}^3/\text{hr}$
Ratio = R160
DN20


Calculate Value of Flowrate Q_1 , Q_2 , Q_3 and Q_4

Constant Value :

The ratio Q_2 / Q_1 shall be 1.6
The ratio Q_4 / Q_3 shall be 1.25

OIML R49-1:2013 4.1

ACCURACY TEST FLOW CHART



TEST PROCEDURE

- ✓ Calculate the flow rate Q_1 , Q_2 and Q_4 from Q_3
- ✓ Key in the flow rate
- ✓ Key in initial meter reading $V_i(i)$
- ✓ Execute the test at flow rate Q_1
- ✓ Key in final meter reading $V_i(f)$

$$V_i = V_i(f) - V_i(i)$$

Preparation	Flowrate Setting	Run Test
Test Result	Maintenance	

Min Flowrate	1688.40	ltr/hr
Max Flowrate	1864.80	ltr/hr
Target Flowrate	1776.60	ltr/hr
Current Flowrate	1776.60	ltr/hr

START	STOP
Speed	33.0 %

Target Volume	10	ltr
---------------	----	-----

SAVE



TEST PROCEDURE

- ✓ Record the final mass of water in the collection tank (V_a)
- ✓ Drain the collection tank
- ✓ Repeat the test for flow rate Q_2 , Q_3 and Q_4
- ✓ Repeat for three (3) consecutive runs
- ✓ Drain piping and unclamp meters
- ✓ Calculate the error using the data
- ✓ Generate report

$$V_a = \frac{Mass}{\rho_{dw}(t)}$$



$$\rho_{dw}(t) = a_0 \frac{(1 + a_1\theta + a_2\theta^2 + a_3\theta^3)}{(1 + a_4\theta + a_5\theta^2)}$$

$$E_m = \frac{V_i - V_a}{V_a} \times 100 \%$$


V_i – Volume determined by the meter [litre]


V_a – Actual volume

$\rho_{dw}(t)$ – Density of water at temperature t , in kg/m³

$Mass$ – Mass of water in kg

ACCURACY TEST CONTROLLER





- ✓ The relative errors (of indication) observed for each of the flow rates shall not exceed the Maximum Permissible Error (MPE). If the error observed on one or more meters is greater than the MPE at one flow rate only, then if only two results have been taken at that flow rate, the test at that flow rate shall be repeated; the test shall be declared satisfactory if two out of the three results at that flow rate lie within the MPE and the arithmetic mean of the results for the three tests at that flow rate lies within the MPE.

- ✓ If all the relative errors (of indication) of a water meter have the same sign, at least one of the errors shall not exceed one-half of the MPE. In all cases, this requirement shall be applied equitably with respect to the water supplier and the consumer.
- ✓ The standard deviation for 7.4.4 a) 1), 2) and 5) shall not exceed one-third of the MPE.

MPE CLASS 2 WATER METER

FLOWRATE ZONE	TEMPERATURE RANGE	
Upper	0.1 °C to 30 °C	> 30 °C
$Q_2 \leq Q \leq Q_4$	$\pm 2 \%$	$\pm 3 \%$
Lower	All Range	
$Q_1 \leq Q < Q_2$	$\pm 5 \%$	

CALIBRATION **PROCEDURES**

DURABILITY TEST

- ✓ During durability tests, the rated operating conditions of the meter shall be met. Where a combination meter consists of individual meters that have been previously approved, only the discontinuous combination meters (additional test) (Table 1) is required. The test is required for forward flow and where appropriate for reverse flow.
- ✓ The orientation(s) of the meters under test shall be set with reference to the meter orientation(s) claimed by the manufacturer.
- ✓ The same meters shall be submitted to the discontinuous and continuous tests.

OIML R49-2:2013 7.11

Table 1 Durability tests

Temperature class	Permanent flow rate Q_3 m ³ /h	Test flow-rate	Test water temperature t_{test} °C ± 5 °C	Type of test	Number of interrupts	Time of pauses	Time of test at test flow rate	Duration of start-up and rundown
T30 and T50	≤ 16	Q_3	20	Dis-continuous	100 000	15 s	15 s	$0.15 [Q_3]^{\frac{1}{2}}$ s with a minimum of 1 s
		Q_4	20	Continuous	—	—	100 h	—
	> 16	Q_3	20	Continuous	—	—	800 h	—
		Q_4	20	Continuous	—	—	200 h	—

OIML R49-2:2013 7.11

DURABILITY TEST



OIML R49-2:2013 7.11.3

OBJECTIVE

- ✓ To verify that a water meter is durable when subjected to cyclic flow conditions.
- ✓ This test is applied only to meters with $Q_3 \leq 16 \text{ m}^3/\text{h}$ and combination meters.
- ✓ The test consists of subjecting the meter to the specified number of starting and stopping flow rate cycles of short duration, the constant test flow rate phase of each cycle being kept at the prescribed flow rate throughout the duration of the test (see 7.11.2.3.2). For the convenience of laboratories, the test can be divided up into periods of at least 6 h.

OIML R49-2:2013 7.11.2

TEST PROCEDURE - DISCONTINUOUS FLOW

- ✓ Set-up the test bench and install the meter under test (MUT).
- ✓ Establish a stable flow (FILL) through the pipeline and MUT until full and gradually increase the pump flow rate to FLUSH out any air bubble.



TEST BENCH FOR DURABILITY



OIML R49-2:2013 7.11

Enabling Businesses. Enhancing Lives

TEST PROCEDURE - DISCONTINUOUS FLOW

NMIM | WATER METER TESTING BENCH | 2019-10-09 11:26:37

TEST PREPARATION TEST SELECTION MAINTENANCE

ENDURANCE START/STOP : ☒ START

SET CYCLES:

CURRENT CYCLES:

WATER METER METROLOGY

SIZE: DN

Q3: m³/h

R = Q3/Q1 (RATIO):

Q1 = Q3/R: m³/h

Q2 = 1.6 X Q1 m³/h

Q4 = 1.25 X Q3 m³/h

RUN TEST STOP FINAL RESULT RESET

ENDURANCE CONTINUOUS : ☒ STOP

SET DURATION (minute)

CURRENT TEST DURATION M S

TEST POINT SELECTION

TARGET FLOWRATE (Q): m³/h

TEST FLOWRATE(Q): m³/h

GRAPHIC PIPE LINE

OIML R49-2:2013 7.11.2

1. Measure the errors (of indication) of the meter(s) as specified in 7.4 and at the same flow rates as in 7.4.4.
2. Mount the meters either singly or in groups in the test rig in the same orientations as those used in determination of the intrinsic errors (of indication).
3. During the tests, maintain the meters within their rated operating conditions and with the pressure downstream of the meters high enough to prevent cavitation in the meters.
4. Adjust the flow rate to within the specified tolerances.

OIML R49-2:2013 7.11.2.3

5. Run the meter(s) at the conditions shown in Table 1 (OIML R49-2).
6. Following the discontinuous durability test, measure the final errors (of indication) of the meters as specified in 7.4 and at the same flow rates as in 7.4.4.
7. Calculate the final relative error (of indication) for each flow rate in accordance with Annex B.
8. For each flow rate, subtract the value of the intrinsic error (of indication) obtained at step 1 from the error (of indication) obtained at step 7.
9. Complete the test report.

OIML R49-2:2013 7.11.2.3

MPE CLASS 2 WATER METER AFTER DISCONTINUOUS TEST

FLOWRATE ZONE	TEMPERATURE RANGE	
Upper	0.1 °C to 30 °C	> 30 °C
$Q_2 \leq Q \leq Q_4$	$\pm 2.5 \%$	$\pm 3.5 \%$
Lower	All Range	
$Q_1 \leq Q < Q_2$	$\pm 6 \%$	

ACCEPTANCE CRITERIA

- ✓ Variation within MPE before and MPE after discontinuous test.
- ✓ The variation in the error curve shall not exceed:

FLOWRATE ZONE	ERROR CURVE VARIATION
Upper	1.5 %
$Q_2 \leq Q \leq Q_4$	
Lower	3 %
$Q_1 \leq Q < Q_2$	

- ✓ For the purpose of determining these requirements, the mean values of the errors (of indication) at each flow rate shall apply.

OIML R49-2:2013 7.11.2.4.2

OBJECTIVE

- ✓ To verify the durability of a water meter when subjected to continuous, permanent, and overload flow conditions.
- ✓ The test consists of subjecting the meter to constant flow rate of Q_3 or Q_4 for a specified duration. In addition, where the small meter of a combination meter has not been pre-approved, the combination meter shall be subjected to a continuous flow test as shown in Table 1. For the convenience of laboratories, the test can be divided up into periods of at least 6 h.

OIML R49-2:2013 7.11.3

TEST PROCEDURE - CONTINUOUS FLOW

NMIM | WATER METER TESTING BENCH 2019-10-11 17:28:44

TEST PREPARATION TEST SELECTION MAINTENANCE

ENDURANCE START/STOP : ● STOP

SET CYCLES: 5

CURRENT CYCLES: 0

ENDURANCE CONTINUOUS : ● START

SET DURATION (minute) 5

CURRENT TEST DURATION 0 M 32 S

WATER METER METROLOGY

SIZE:	0	DN
Q3:	2.50	m ³ /h
R = Q3/Q1 (RATIO):	1.6000	
Q1 = Q3/R:	0.02	m ³ /h
Q2 = 1.6 X Q1	0.03	m ³ /h
Q4 = 1.25 X Q3	3.12	m ³ /h

TEST POINT SELECTION

TARGET FLOWRATE (Q):	2.5	m ³ /h
TEST FLOWRATE(Q):	2.39	m ³ /h

RUN TEST STOP FINAL RESULT RESET GRAPHIC PIPE LINE

OIML R49-2:2013 7.11.3

1. Measure the errors (of indication) of the meter(s) as specified in 7.4 and at the same flow rates as in 7.4.4.
2. Mount the meters either singly or in groups in the test rig in the same orientations as those used in determination of the intrinsic errors (of indication).
3. Run the meter(s) at the conditions shown in Table 1 (OIML R49-2).
4. Throughout the durability tests, the meter(s) shall be held within their rated operating conditions and the pressure at the outlet of each meter shall be high enough to prevent cavitation.

OIML R49-2:2013 7.11.3.3

5. After the continuous durability test(s), measure the errors (of indication) of the meter(s) as specified in 7.4 and at the same flow rates
6. Calculate the relative error (of indication) for each flow rate in accordance with Annex B.
7. For each flow rate, subtract the value of the intrinsic error (of indication) obtained at step 1 of 7.11.2.3.1 from the error (of indication) obtained at step 7.
8. Complete the test report.

OIML R49-2:2013 7.11.3.3

MPE CLASS 2 WATER METER AFTER CONTINUOUS TEST

FLOWRATE ZONE	TEMPERATURE RANGE	
Upper	0.1 °C to 30 °C	> 30 °C
$Q_2 \leq Q \leq Q_4$	$\pm 2.5 \%$	$\pm 3.5 \%$
Lower	All Range	
$Q_1 \leq Q < Q_2$	$\pm 6 \%$	

ACCEPTANCE CRITERIA

- ✓ Variation within MPE before continuous and MPE after continuous test.
- ✓ The variation in the error curve shall not exceed:

FLOWRATE ZONE	ERROR CURVE VARIATION
Upper $Q_2 \leq Q \leq Q_4$	1.5 %
Lower $Q_1 \leq Q < Q_2$	
	3 %

- ✓ For the purpose of determining these requirements, the mean values of the errors (of indication) at each flow rate shall apply.

OIML R49-2:2013 7.11.3.4.2